

Asbestos Registry

Healthcare Facilities within Prairie North Health Region



Facility Name: Battlefords Union Hospital
Location: 1092 - 107th Street
 North Battleford, SK
Date: November 14, 2014
Contact Person: Lloyd Bullock, Director of Environmental Services
 Telephone 306 820 2582
 Email - lloyd.bullock@pnrha.ca

Type of Asbestos Containing Material	Location	Characteristics	Accessibility
Pipeline fitting compound	Mechanical room, basement Mental Health wing: consider all fittings as asbestos containing	70% Chrysotile	Low, restricted to limited staff
Pipeline fitting compound	Mechanical room, main floor: consider all fittings as asbestos containing	60% Chrysotile	Low, restricted to limited staff
Pipeline fitting compound	Mechanical room, 3rd floor: consider all fittings as asbestos containing	70% Chrysotile	Low, restricted to limited staff
Pipeline fitting compound	Mechanical room, 4th floor: consider all fittings as asbestos containing	75% Chrysotile	Low, restricted to limited staff
Sheet flooring	Corridor, west of main floor boiler room	30% Chrysotile, off white squares	Moderate, limited staff access