Asbestos Registry
Healthcare Facilities within Prairie North Health Region

Facility Name: Dr. Cooke Extended Care Centre
Location: 3915 - 56 Avenue
Lloydminster, AB
Date: November 14, 2014
Contact Person: Lloyd Bullock, Director of Environmental Services
Telephone 306 820 2582
Email - lloyd.bullock@pnrha.ca

Type of Asbestos Containing Material	Location	Characteristics	Accessibility
Gypsum taping compound	Suspect all walls and ceilings in central and south units	1-5% Chrysotile	Low, non friable
Floor leveling compound	Suspect all floors in central and south units	1-5% Chrysotile	High, friable
Acoustical ceiling spray	Chapel, room #58	5-10% Chrysotile	Medium, friable
Floor tile, 12" x 12"	Numerous locations	1-5% Chrysotile, Red with white specs	High, non friable
Floor tile, 12" x 12"	Numerous locations	1-5% Chrysotile, Beige with gray and white streaks	High, non friable
Sheet flooring	Numerous locations, basement stairwell	40% Chrysotile, Red, brown and beige stone pattern	High, non friable
Pipeline fitting	Basement corridor, above closed ceiling	30% Chrysotile on small foil-wrapped line	Low, friable
Pipeline fitting	Basement crawl spaces, north and south	25% Chrysotile on small foil-wrapped line	Low, friable

Asbestos Registry

Healthcare Facilities within Prairie North Health Region