

## Asbestos Registry

### Healthcare Facilities within the Prairie North Health Region



**Facility Name:** River Heights Lodge

**Location:** 2001 - 99 Street

North Battleford, SK

**Date:** Nov 14, 2014

**Contact Person:** Lloyd Bullock, Director of Environmental Services

**Telephone (306) 820-2582**

**Email - lloyd.bullock@pnrha.ca**

Type of Asbestos Containing Material	Location	Characteristics	Accessibility
Pipeline fitting compound	Corridor 231, above ceiling tiles	10 - 15% Chrysotile, friable	Low, limited access
Pipeline fitting compound	Corridor 232, above ceiling tiles	10 -15% Chrysotile, friable	Low, limited access
Pipeline fitting compound	Corridor 233, above ceiling tiles	10 - 15% Chrysotile, friable	Low, limited access
Sheet flooring	Corridor 234	40% Chrysotile, non friable, yellow with larger off white squares	High
Pipeline fitting compound	Corridor 236, above ceiling tiles	10 - 15% Chrysotile, friable	Low, limited access
Pipeline fitting compound	Corridor 328, above ceiling tiles	30% Chrysotile, friable	Low, limited access
Floor tile	Corridor 329	1 - 5% Chrysotile, non friable, beige with fine brown streaks	High
Floor tile	Corridor 331	1 - 5% Chrysotile, non friable, beige with fine brown streaks	High
Pipeline fitting compound	Corridor 331, above ceiling tiles	30% Chrysotile, friable	Low, limited access
Pipeline fitting compound	Corridor 337 above the ceiling tile adjacent the north exit doors	30% Chrysotile, friable	Low, limited access
Floor tile	Corridor 337	1 - 5% Chrysotile, non friable, beige with fine brown streaks	High
Pipeline fitting compound	Corridor 337, above ceiling tile adjacent room 301	30% Chrysotile, friable	Low, limited access
Pipeline fitting compound	Corridor 337, above ceiling tiles, adjacent rooms 205 and 207	10-15% Chrysotile, friable	Low, limited access
Floor tile	Corridor 346	1 - 5% Chrysotile, non friable, beige with fine brown streaks	High

## Asbestos Registry

### Healthcare Facilities within the Prairie North Health Region

Type of Asbestos Containing Material	Location	Characteristics	Accessibility
Pipeline fitting compound	Corridor 418, above ceiling tile in : 1 - adjacent room 403, 1 - adjacent room 405, 5 - adjacent room 411, 1 - adjacent room 415, 2 - adjacent south exit door, 3 - adjacent corridor 355, 2 - ten feet south of room 401	30% Chrysotile ,friable	Low, limited access
Floor tile	Corridor231	1 - 5% Chrysotile,non friable, beige with fine brown steaks	High
Floor tile	Corridor233	1 - 5% Chrysotile,non friable, beige with fine brown steaks	High
Floor tile	Corridor236	1 - 5% Chrysotile,non friable, beige with fine brown steaks	High
Pipeline fitting compound	Basement, east corridor, above ceiling tiles adjacent maintenance office	30% Chrysotile, friable	Low, limited access
Pipeline fitting compound	Basement, east, north storage room, visible pipeline fitting near ceiling	30% Chrysotile, friable	Low, limited access
Pipeline fitting compound	Basement, east, Recreation Storage room, visible pipeline fitting, near ceiling	30% Chrysotile, friable	Moderate, limited staff in area
Pipeline fitting compound	Basement, east, Southeast storage room, overhead pipeline fitting, southeast corner of room	30% Chrysotile, friable	Moderate, limited staff in area
Fire-stop material	Basement, east, southeast storage room at the duct penetration into south wall, near ceiling	60% Chrysotile,friable	Moderate, limited staff in area
Pipeline fitting compound	Basement, east boiler room, medium overhead line straight north of the entry	10% Chrysotile, friable	Low, limited access

## Asbestos Registry

### Healthcare Facilities within the Prairie North Health Region

Type of Asbestos Containing Material	Location	Characteristics	Accessibility
Duct Expansion Gasket	Basement, east boiler room, on boiler	20% Chrysotile, non friable	low, restricted access
Pipeline fitting compound debris	Basement, east Boiler room, pipe chase, west side of boiler room	10% Chrysotile, friable	Low, limited access
Fire-stop material	Basement, west crawl space, all areas beyond compressors consider loose material in dirt	60% Chrysotile, friable	Low, restricted access
Sheet flooring	Kitchen, Cooler room 14.1	40% Chrysotile, non friable, yellow with larger off white squares	Moderate
Sheet flooring	Kitchen, Cooler room 14.2	40% Chrysotile, non friable, yellow with larger off white squares	Moderate
Sheet flooring	kitchen, Cooler room 14.3	40% Chrysotile, non friable, yellow with larger off white squares	Moderate
Floor tile	Corridor 324, alcove, 331.1	1 - 5% Chrysotile, non friable, beige with fine brown streaks	High
Fire Stop Material	Room 13, staff lounge, above closed ceiling as seen from access hatches	60% Chrysotile, friable	Low, restricted access
Sheet flooring	Room 155, laundry	40% Chrysotile, non friable, white with gray irregular shapes	Low, limited staff access
Sheet flooring	Room 165.1, east vestibule	40% Chrysotile, non friable, white with gray irregular shapes	Low
Floor tile	Room 201, resident room	1 - 5% Chrysotile, non friable, beige with fine brown streaks	High
Floor tile	Room 201.12, resident washroom	1 - 5% Chrysotile, non friable, beige with fine brown streaks	High
Floor tile	Room 202, resident room	1 - 5% Chrysotile, non friable, beige with fine brown streaks	High
Floor tile	Room 202.1, resident washroom	1 - 5% Chrysotile, non friable, beige with fine brown streaks	High
Floor tile	Room 203, resident room	1 - 5% Chrysotile, non friable, beige with fine brown streaks	High

## Asbestos Registry

### Healthcare Facilities within the Prairie North Health Region

Type of Asbestos Containing Material	Location	Characteristics	Accessibility
Floor tile	Room 204, resident room	1 - 5% Chrysotile, non friable, beige with fine brown streaks	High
Floor tile	Room 204.1, resident wash room	1 - 5% Chrysotile, non friable, beige with fine brown streaks	High
Floor tile	Room 205, resident room	1 - 5% Chrysotile, non friable, beige with fine brown streaks	High
Floor tile	Room 205.1, resident washroom	1 - 5% Chrysotile, non friable, beige with fine brown streaks	High
Floor tile	Room 206, resident room	1 - 5% Chrysotile, non friable, beige with fine brown streaks	High
Pipeline fitting compound	Room 206, resident room, above ceiling tile	1 - 5% Chrysotile, non friable, beige with fine brown streaks	Low, limited access
Floor tile	Room 207, resident room	1 - 5% Chrysotile, non friable, beige with fine brown streaks	High
Pipeline fitting compound	Room 207, resident room, above ceiling tile	10-15% Chrysotile, non friable	Low, limited access
Sheet flooring	Room 208, resident room	40% Chrysotile, non friable, yellow with larger off white squares	High
Sheet flooring	Room 208.1, resident washroom	40% Chrysotile, non friable, yellow with larger off white squares	High
Sheet flooring	Room 209, resident room	40% Chrysotile, non friable, yellow with larger off white squares	High
Sheet flooring	Room 210, resident room	40% Chrysotile, non friable, yellow with larger off white squares	High
Sheet flooring	Room 210.1, resident washroom	40% Chrysotile, non friable, yellow with larger off white squares	High
Sheet flooring	Room 211, resident room	40% Chrysotile, non friable, yellow with larger off white squares	High
Sheet flooring	Room 211.1, resident washroom	40% Chrysotile, non friable, yellow with larger off white squares	High
Sheet flooring	Room 212, resident room	40% Chrysotile, non friable, yellow with larger off white squares	High

## Asbestos Registry

### Healthcare Facilities within the Prairie North Health Region

Type of Asbestos Containing Material	Location	Characteristics	Accessibility
Sheet flooring	Room 212.1, resident washroom	40% Chrysotile, non friable, yellow with larger off white squares	High
Sheet flooring	Room 213, resident room	40% Chrysotile, non friable, yellow with larger off white squares	High
Sheet flooring	Room 213.1, resident washroom	40% Chrysotile, non friable, yellow with larger off white squares	High
Sheet flooring	Room 214, resident room	40% Chrysotile, non friable, yellow with larger off white squares	High
Sheet flooring	Room 214.1, resident washroom	40% Chrysotile, non friable, yellow with larger off white squares	High
Sheet flooring	Room 215, resident room	40% Chrysotile, non friable, yellow with larger off white squares	High
Sheet flooring	Room 215.1, resident washroom	40% Chrysotile, non friable, yellow with larger off white squares	High
Floor tile	Room 216.1, resident washroom	1 - 5% Chrysotile, non friable, beige with fine brown streaks	High
Floor tile	Room 217, resident room	1 - 5% Chrysotile, non friable, beige with fine brown streaks	High
Floor tile	Room 217.1, resident washroom	1 - 5% Chrysotile, non friable, beige with fine brown streaks	High
Floor tile	Room 218, resident room	1 - 5% Chrysotile, non friable, beige with fine brown streaks	High
Floor tile	Room 219, resident room	1 - 5% Chrysotile, non friable, beige with fine brown streaks	High
Floor tile	Room 219.1, resident washroom	1 - 5% Chrysotile, non friable, beige with fine brown streaks	High
Floor tile	Room 220, resident room	1 - 5% Chrysotile, non friable, beige with fine brown streaks	High
Floor tile	Room 220.1, resident washroom	1 - 5% Chrysotile, non friable, beige with fine brown streaks	High
Floor tile	Room 221, resident room	1 - 5% Chrysotile, non friable, beige with fine brown streaks	High

## Asbestos Registry

### Healthcare Facilities within the Prairie North Health Region

Type of Asbestos Containing Material	Location	Characteristics	Accessibility
Floor tile	Room 222, resident room	1 - 5% Chrysotile, non friable, beige with fine brown streaks	High
Sheet flooring	Room 223 washroom	40% Chrysotile, non friable, white with gray irregular shapes	Moderate
Floor tile	Room 223, resident room	1 - 5% Chrysotile, non friable, beige with fine brown streaks	High
Floor tile	Room 224, resident room	1 - 5% Chrysotile, non friable, beige with fine brown streaks	High
Floor tile	Room 224.1, resident washroom	1 - 5% Chrysotile, non friable, beige with fine brown streaks	High
Floor tile	Room 225, resident room	1 - 5% Chrysotile, non friable, beige with fine brown streaks	High
Floor tile	Room 226, resident room	1 - 5% Chrysotile, non friable, beige with fine brown streaks	High
Floor tile	Room 227, resident room	1 - 5% Chrysotile, non friable, beige with fine brown streaks	High
Sheet flooring	Room 227.1, resident washroom	40% Chrysotile, non friable, white with gray irregular shapes	High
Floor tile	Room 228, resident room	1 - 5% Chrysotile, non friable, beige with fine brown streaks	High
Floor tile	Room 228.1, resident washroom	1 - 5% Chrysotile, non friable, beige with fine brown streaks	High
Floor tile	Room 229, resident room	1 - 5% Chrysotile, non friable, beige with fine brown streaks	High
Pipeline fitting compound	Room 229, residents room, near ceiling	10 - 15% Chrysotile, friable	Low, limited access
Floor tile	Room 230, resident room	1 - 5% Chrysotile, non friable, beige with fine brown streaks	High
Pipeline fitting compound	Room 230, residents room, near ceiling	10 - 15% Chrysotile, friable	Low, limited access
Sheet flooring	Room 235 vestibule	40% Chrysotile, non friable, yellow with larger off white squares	Moderate

## Asbestos Registry

### Healthcare Facilities within the Prairie North Health Region

Type of Asbestos Containing Material	Location	Characteristics	Accessibility
Floor tile	Room 237, electrical	1 - 5% Chrysotile, non friable, beige with fine brown streaks	Low, limited access
Floor tile	Room 240, Physio therapy	1 - 5% Chrysotile, non friable, beige with fine brown streaks	High
Floor tile	Room 241, Oxygen storage	1 - 5% Chrysotile, non friable, beige with fine brown streaks	Moderate, limited access
Floor tile	Room 301, resident room	1 - 5% Chrysotile, non friable, beige with fine brown streaks	High
Floor tile	Room 302, resident room	1 - 5% Chrysotile, non friable, beige with fine brown streaks	High
Sheet flooring	Room 302.1, resident washroom	40% Chrysotile, non friable, white with gray irregular shapes	High
Floor tile	Room 303, resident room	1 - 5% Chrysotile, non friable, beige with fine brown streaks	High
Floor tile	Room 303.1, resident washroom	1 - 5% Chrysotile, non friable, beige with fine brown streaks	High
Floor tile	Room 304, resident room	1 - 5% Chrysotile, non friable, beige with fine brown streaks	High
Floor tile	Room 304.1, resident washroom	1 - 5% Chrysotile, non friable, beige with fine brown streaks	High
Floor tile	Room 305, resident room	1 - 5% Chrysotile, non friable, beige with fine brown streaks	High
Floor tile	Room 306, resident room	1 - 5% Chrysotile, non friable, beige with fine brown streaks	High
Floor tile	Room 307, resident room	1 - 5% Chrysotile, non friable, beige with fine brown streaks	High
Floor tile	Room 308, resident room	1 - 5% Chrysotile, non friable, beige with fine brown streaks	High
Sheet flooring	Room 308.1, resident washroom	40% Chrysotile, non friable, white with gray irregular shapes	High
Floor tile	Room 309, resident room	1 - 5% Chrysotile, non friable, beige with fine brown streaks	High

## Asbestos Registry

### Healthcare Facilities within the Prairie North Health Region

Type of Asbestos Containing Material	Location	Characteristics	Accessibility
Floor tile	Room 310, resident room	1 - 5% Chrysotile, non friable, beige with fine brown streaks	High
Sheet flooring	Room 311.1, resident washroom	40% Chrysotile, non friable, white with gray irregular shapes	High
Floor tile	Room 312, resident room	1 - 5% Chrysotile, non friable, beige with fine brown streaks	High
Floor tile	Room 312.1, resident washroom	1 - 5% Chrysotile, non friable, beige with fine brown streaks	High
Floor tile	Room 313, resident room	1 - 5% Chrysotile, non friable, beige with fine brown streaks	High
Pipeline fitting compound	Room 313, resident room, near ceiling	30% Chrysotile, friable	Low, limited access
Floor tile	Room 314, resident room	1 - 5% Chrysotile, non friable, beige with fine brown streaks	High
Pipeline fitting compound	Room 314, resident room, near ceiling	30% Chrysotile, friable	Low, limited access
Floor tile	Room 315, resident room	1 - 5% Chrysotile, non friable, beige with fine brown streaks	High
Sheet flooring	Room 315.1, resident washroom	40% Chrysotile, non friable, white with gray irregular shapes	High
Sheet flooring	Room 320.1, resident washroom	40% Chrysotile, non friable, white with gray irregular shapes	High
Sheet flooring	Room 321.1, resident washroom	40% Chrysotile, non friable, white with gray irregular shapes	High
Sheet flooring	Room 324.1, resident washroom	40% Chrysotile, non friable, white with gray irregular shapes	High
Pipeline fitting compound	Room 326, resident room, near ceiling	30% Chrysotile, friable	Low, limited access
Pipeline fitting compound	Room 327, resident room, near ceiling	30% Chrysotile, friable	Low, limited access
Floor tile	Room 334, NUC office	1 - 5% Chrysotile, non friable, beige with fine brown streaks	Moderate, limited access



## Asbestos Registry

### Healthcare Facilities within the Prairie North Health Region

Type of Asbestos Containing Material	Location	Characteristics	Accessibility
Floor tile	Room 334.1 ,NUC office	1 - 5% Chrysotile,non friable, beige with fine brown steaks	Moderate, limited access
Floor tile	Room 338, staff	1 - 5% Chrysotile,non friable, beige with fine brown steaks	High
Pipeline fitting compound	Room 339, linen, near ceiling	30% Chrysotile, friable	Low, limited access
Sheet flooring	Room 340, staff washroom	40% Chrysotile, non friable, white with gray irregular shapes	High
Pipeline fitting compound	Room 341-Dining area, above ceiling tiles in cement blocks, above west fire doors	50% Chrysotile, friable	Low, limited access
Insulation, Vermiculite	Room 341-Dining area, above ceiling tiles, in cement blocks, above west fire doors	Actinolite/Tremolite >0.1%, friable	Low, limited access
Floor tile	Room 343	1 - 5% Chrysotile,non friable, beige with fine brown steaks	High
Pipeline fitting compound	Room 347, maintenance shop, ceiling	30% Chrysotile, friable	Low, limited access
Floor tile	Room 348, maintenance storage	1 - 5% Chrysotile,non friable, beige with fine brown steaks	Moderate, limited access
Pipeline fitting compound	Room 348, maintenance storage, near ceiling, 2 fittings	10% Chrysotile, friable	Low, limited access
Floor tile	Room 348.1, washroom	1 - 5% Chrysotile,non friable, beige with fine brown steaks	Moderate, limited access
Sheet flooring	Room 349, Female staff	40% Chrysotile, non friable, yellow with larger off white squares	High
Sheet flooring	Room 349.1, Female staff washroom	40% Chrysotile, non friable, yellow with larger off white squares	High
Pipeline fitting compound	Room 351, stairwell, larger of small green lines	30% Chrysotile, friable	Low, limited access
Pipeline fitting compound	Room 352, Storage	30% Chrysotile, friable	Low, limited access
Pipeline fitting compound	Room 354, stairwell, larger of small green lines	30% Chrysotile, friable	Low, limited access

## Asbestos Registry

### Healthcare Facilities within the Prairie North Health Region

Type of Asbestos Containing Material	Location	Characteristics	Accessibility
Floor tile	Room 400.2, service room	1 - 5% Chrysotile, non friable, beige with fine brown streaks	Low, limited access
Floor tile	Room 402	1 - 5% Chrysotile, non friable, beige with fine brown streaks	Moderate, limited access
Sheet flooring	Room 402.1, washroom	40% Chrysotile, non friable, white with gray irregular shapes	Moderate, limited access
Floor tile	Room 403, laundry	1 - 5% Chrysotile, non friable, beige with fine brown streaks	Low, limited access
Sheet flooring	Room 403.1, washroom	40% Chrysotile, non friable, white with gray irregular shapes	Moderate, limited access
Sheet flooring	Room 404.1, washroom	40% Chrysotile, non friable, white with gray irregular shapes	Moderate, limited access
Floor tile	Room 405	1 - 5% Chrysotile, non friable, beige with fine brown streaks	Moderate, limited access
Floor tile	Room 406	1 - 5% Chrysotile, non friable, beige with fine brown streaks	Moderate, limited access
Sheet flooring	Room 407.1, washroom	40% Chrysotile, non friable, white with gray irregular shapes	Moderate, limited access
Floor tile	Room 408	1 - 5% Chrysotile, non friable, beige with fine brown streaks	Moderate, limited access
Floor tile	Room 409	1 - 5% Chrysotile, non friable, beige with fine brown streaks	Moderate, limited access
Sheet flooring	Room 409.1, washroom	40% Chrysotile, non friable, white with gray irregular shapes	Moderate, limited access
Floor tile	Room 410	1 - 5% Chrysotile, non friable, beige with fine brown streaks	Moderate, limited access
Floor tile	Room 410	1 - 5% Chrysotile, non friable, beige with fine brown streaks	Moderate, limited access
Sheet flooring	Room 410.1, washroom	40% Chrysotile, non friable, white with gray irregular shapes	Moderate, limited access
Sheet flooring	Room 411.1, washroom	40% Chrysotile, non friable, white with gray irregular shapes	Moderate, limited access

## Asbestos Registry

### Healthcare Facilities within the Prairie North Health Region

Type of Asbestos Containing Material	Location	Characteristics	Accessibility
Floor tile	Room 412	1 - 5% Chrysotile, non friable, beige with fine brown streaks	Moderate, limited access
Sheet flooring	Room 412.1, washroom	40% Chrysotile, non friable, white with gray irregular shapes	Moderate, limited access
Floor tile	Room 414	1 - 5% Chrysotile, non friable, beige with fine brown streaks	Moderate, limited access
Pipeline fitting compound	Room 414, visible pipeline near ceiling	30% Chrysotile, friable	Low, limited access
Sheet flooring	Room 414.1, washroom	40% Chrysotile, non friable, white with gray irregular shapes	Moderate, limited access
Floor tile	Room 415	1 - 5% Chrysotile, non friable, beige with fine brown streaks	Moderate, limited access
Floor tile	Room 417	1 - 5% Chrysotile, non friable, beige with fine brown streaks	Moderate, limited access
Sheet flooring	Room 419, storage	40% Chrysotile, non friable, white with gray irregular shapes	Moderate, limited access
Floor tile	Room 421	1 - 5% Chrysotile, non friable, beige with fine brown streaks	Moderate, limited access
Sheet flooring	Room 421.1, washroom	40% Chrysotile, non friable, white with gray irregular shapes	Moderate, limited access
Pipeline fitting compound	Room 422, common area, near ceiling	30% Chrysotile, friable	Low, limited access
Floor tile	Room 422.1, closet	1 - 5% Chrysotile, non friable, beige with fine brown streaks	Low, limited access
Floor tile	Room 423	1 - 5% Chrysotile, non friable, beige with fine brown streaks	Moderate, limited access
Floor tile	Room 424	1 - 5% Chrysotile, non friable, beige with fine brown streaks	Moderate, limited access
Sheet flooring	Room 424.1, washroom	40% Chrysotile, non friable, white with gray irregular shapes	Moderate, limited access
Floor tile	Room 425	1 - 5% Chrysotile, non friable, beige with fine brown streaks	Moderate, limited access

