

Asbestos Register for 0022-01 N Bttlfrd - SHNB Main Blg

Facility Type: Hospital
Region: Saskatoon
Owner: Ministry of Central Services
Address: Sask Hospital Grounds , North Battleford S9A 2X8
Building Name: 0022-01 N Bttlfrd - SHNB Main Blg
Contact Person: Sankey, Dan **Title:** Building Manager
Phone: 446-7792 **Email:** dan.sankey@gov.sk.ca

Date Reported	Type	Friable	Location / Characteristics	Concentration	Accessibility
Mar 13, 2013	Chrysotile	<input checked="" type="checkbox"/>	Main Building- 5000 Mechanical Room - Mud compound from small tank	50	B
Mar 13, 2013	Chrysotile	<input checked="" type="checkbox"/>	Main Building- Basement Tunnel - Fire stop material at pipe penetration above tunnel entry door		B
Mar 13, 2013	Chrysotile	<input checked="" type="checkbox"/>	Main Building- Basement Tunnel - Pipeline fitting on medium white line, adjacent basement chapel entry	60	B
Mar 13, 2013	Amosite/ Chrysotile	<input checked="" type="checkbox"/>	Main Building- Basement Tunnel - Lineal pipe insulation from medium white line, above head in the middle of tunnel		B

Accessibility: A - accessible to all building occupants, B - accessible to maintenance and operations staff only, C - accessible to maintenance and operations staff with a ladder only, D - not accessible due to physical barrier

Asbestos Register for 0022-02 N Bttlfrd - Industrial Therapy Bldg

Facility Type: Hospital
Region: Saskatoon
Owner: Ministry of Central Services
Address: Sask Hospital Grounds , North Battleford S9A 2X8
Building Name: 0022-02 N Bttlfrd - Industrial Therapy Bldg
Contact Person: Sankey, Dan **Title:** Building Manager
Phone: 446-7792 **Email:** dan.sankey@gov.sk.ca

Date Reported	Type	Friable	Location / Characteristics	Concentration	Accessibility
Mar 13, 2013	Chrysotile	<input checked="" type="checkbox"/>	Industrial Therapy Building- Wood Shop - Lineal pipe insulation from medium brown line, close to entry door	60	A
Mar 13, 2013	Chrysotile	<input checked="" type="checkbox"/>	Industrial Therapy Building- Wood Shop - Pipeline fitting on medium brown line, close to entry door	50	A

Accessibility: A - accessible to all building occupants, B - accessible to maintenance and operations staff only, C - accessible to maintenance and operations staff with a ladder only, D - not accessible due to physical barrier

Asbestos Register for 0022-03 N Bttlfrd - Power House

Facility Type: Hospital
Region: Saskatoon
Owner: Ministry of Central Services
Address: Sask Hospital Grounds , North Battleford S9A 2X8
Building Name: 0022-03 N Bttlfrd - Power House
Contact Person: Sankey, Dan **Title:** Building Manager
Phone: 446-7792 **Email:** dan.sankey@gov.sk.ca

Date Reported	Type	Friable	Location / Characteristics	Concentration	Accessibility
Mar 13, 2013	Chrysotile	<input checked="" type="checkbox"/>	Boiler House- Boiler Room - Pipeline fitting on medium white line, on 2nd level mezzanine, adjacent metal hand rail		B
Mar 13, 2013	Amosite/ Chrysotile	<input checked="" type="checkbox"/>	Boiler House- Boiler Room - Duct insulation from large white ducting		B
Mar 13, 2013	Amosite/ Chrysotile	<input checked="" type="checkbox"/>	Boiler House- Boiler Room - Lineal pipe insulation from medium white line, adjacent 2nd level mezzanine entry door		B
Mar 13, 2013	Chrysotile	<input checked="" type="checkbox"/>	Boiler House- Boiler Room - Pipeline fitting on large white line, below white tank	60	B

Accessibility: A - accessible to all building occupants, B - accessible to maintenance and operations staff only, C - accessible to maintenance and operations staff with a ladder only, D - not accessible due to physical barrier

Asbestos Register for 0022-04 N Bttlfrd - Laundry Bldg

Facility Type: Hospital
Region: Saskatoon
Owner: Ministry of Central Services
Address: Sask Hospital Grounds , North Battleford S9A 2X8
Building Name: 0022-04 N Bttlfrd - Laundry Bldg
Contact Person: Sankey, Dan **Title:** Building Manager
Phone: 446-7792 **Email:** dan.sankey@gov.sk.ca

Date Reported	Type	Friable	Location / Characteristics	Concentration	Accessibility
Mar 13, 2013	Chrysotile	<input checked="" type="checkbox"/>	Laundry Building- Basement - Pipeline fitting on small white line, in corner of basement adjacent fan unit	40	A
Mar 13, 2013	Amosite/ Chrysotile	<input checked="" type="checkbox"/>	Laundry Building- Basement - Lineal pipe insulation from medium white line, in corner of basement adjacent fan unit		B

Accessibility: A - accessible to all building occupants, B - accessible to maintenance and operations staff only, C - accessible to maintenance and operations staff with a ladder only, D - not accessible due to physical barrier

Asbestos Register for 0022-06 N Bttlfrd - Cottage 25

Facility Type: Residence
Region: Saskatoon
Owner: Ministry of Central Services
Address: Sask Hospital Grounds , North Battleford S9A-2X8
Building Name: 0022-06 N Bttlfrd - Cottage 25
Contact Person: Sankey, Dan **Title:** Building Manager
Phone: 446-7792 **Email:** dan.sankey@gov.sk.ca

Date Reported	Type	Friable	Location / Characteristics	Concentration	Accessibility
Mar 15, 2013	Chrysotile	<input checked="" type="checkbox"/>	Cottage 25- Basement - Pipeline fitting on small line, adjacent window		B

Accessibility: A - accessible to all building occupants, B - accessible to maintenance and operations staff only, C - accessible to maintenance and operations staff with a ladder only, D - not accessible due to physical barrier

Asbestos Register for 0022-09 N Bttlfrd - Correctional Centre

Facility Type: Correctional Centre/Facility
Region: Saskatoon
Owner: Ministry of Central Services
Address: Sask Hospital Grounds , North Battleford S9A 3E6
Building Name: 0022-09 N Bttlfrd - Correctional Centre
Contact Person: Sankey, Dan **Title:** Building Manager
Phone: 446-7792 **Email:** dan.sankey@gov.sk.ca

Date Reported	Type	Friable	Location / Characteristics	Concentration	Accessibility
Mar 13, 2013	Chrysotile	<input checked="" type="checkbox"/>	Community Corrections Centre- Basement Fan Room - Pipeline fitting on medium white line, adjacent ducting		B
Mar 13, 2013	Chrysotile	<input checked="" type="checkbox"/>	Community Corrections Centre- Basement - Pipeline fitting on large white line, adjacent 2001.1 entry door	40	A
Mar 13, 2013	Chrysotile	<input checked="" type="checkbox"/>	Community Corrections Centre- Basement - Lineal pipe insulation from brown line, adjacent 2001.1 entry door		A

Accessibility: A - accessible to all building occupants, B - accessible to maintenance and operations staff only, C - accessible to maintenance and operations staff with a ladder only, D - not accessible due to physical barrier

Asbestos Register for 0022-10 N Bttlfrd - Green House

Facility Type: Greenhouse
Region: Saskatoon
Owner: Ministry of Central Services
Address: Sask Hospital Grounds , North Battleford S9A 2X8
Building Name: 0022-10 N Bttlfrd - Green House
Contact Person: Sankey, Dan **Title:** Building Manager
Phone: 446-7792 **Email:** dan.sankey@gov.sk.ca

Date Reported	Type	Friable	Location / Characteristics	Concentration	Accessibility
Mar 13, 2013	Chrysotile	<input checked="" type="checkbox"/>	Greenhouse- Basement - Lineal pipe insulation from small white line, adjacent stairs	75	A
Mar 13, 2013	Chrysotile	<input checked="" type="checkbox"/>	Greenhouse- Basement - Pipeline fitting on small white line, adjacent shelf	60	A

Accessibility: A - accessible to all building occupants, B - accessible to maintenance and operations staff only, C - accessible to maintenance and operations staff with a ladder only, D - not accessible due to physical barrier

Asbestos Register for 0022-16 N Bttlfrd - Curling Rink

Facility Type: Recreation Facility
Region: Saskatoon
Owner: Ministry of Central Services
Address: Sask Hospital Grounds , North Battleford S9A 2X8
Building Name: 0022-16 N Bttlfrd - Curling Rink
Contact Person: Sankey, Dan **Title:** Building Manager
Phone: 446-7792 **Email:** dan.sankey@gov.sk.ca

Date Reported	Type	Friable	Location / Characteristics	Concentration	Accessibility
Apr 30, 2014	Asbestos	<input type="checkbox"/>	Various Locations - ENCAPSULATED		

Accessibility: A - accessible to all building occupants, B - accessible to maintenance and operations staff only, C - accessible to maintenance and operations staff with a ladder only, D - not accessible due to physical barrier

Asbestos Register for 0022-17 N Bttlfrd - Paint Shop

Facility Type: Workshop
Region: Saskatoon
Owner: Ministry of Central Services
Address: Sask Hospital Grounds , North Battleford S9A 2X8
Building Name: 0022-17 N Bttlfrd - Paint Shop
Contact Person: Sankey, Dan **Title:** Building Manager
Phone: 446-7792 **Email:** dan.sankey@gov.sk.ca

Date Reported	Type	Friable	Location / Characteristics	Concentration	Accessibility
Apr 30, 2014	Asbestos	<input type="checkbox"/>	Various Locations - ENCAPSULATED		

Asbestos Register for 0022-18 N Bttlfrd - Dormitory

Facility Type: Hospital
Region: Saskatoon
Owner: Ministry of Central Services
Address: Sask Hospital Grounds , North Battleford S9A 2X8
Building Name: 0022-18 N Bttlfrd - Dormitory
Contact Person: Sankey, Dan **Title:** Building Manager
Phone: 446-7792 **Email:** dan.sankey@gov.sk.ca

Date Reported	Type	Friable	Location / Characteristics	Concentration	Accessibility
Apr 30, 2014	Asbestos	<input type="checkbox"/>	Various Locations - ENCAPSULATED		

Accessibility: A - accessible to all building occupants, B - accessible to maintenance and operations staff only, C - accessible to maintenance and operations staff with a ladder only, D - not accessible due to physical barrier



Asbestos Register for 0022-19 N Bttlfrd - Quonset

Facility Type: Warehouse/General storage
Region: Saskatoon
Owner: Ministry of Central Services
Address: Sask Hospital Grounds , North Battleford S9A 2X8
Building Name: 0022-19 N Bttlfrd - Quonset
Contact Person: Sankey, Dan **Title:** Building Manager
Phone: 446-7792 **Email:** dan.sankey@gov.sk.ca

Date Reported	Type	Friable	Location / Characteristics	Concentration	Accessibility
Mar 13, 2013	Chrysotile	<input checked="" type="checkbox"/>	Quonset- Storage Area - Lineal pipe insulation from white line, coming from unit heater		C

Accessibility: A - accessible to all building occupants, B - accessible to maintenance and operations staff only, C - accessible to maintenance and operations staff with a ladder only, D - not accessible due to physical barrier

Asbestos Register for 0022-20 N Bttlfrd - Maint Shop

Facility Type: Workshop
Region: Saskatoon
Owner: Ministry of Central Services
Address: Sask Hospital Grounds , North Battleford S9A 2X8
Building Name: 0022-20 N Bttlfrd - Maint Shop
Contact Person: Sankey, Dan **Title:** Building Manager
Phone: 446-7792 **Email:** dan.sankey@gov.sk.ca

Date Reported	Type	Friable	Location / Characteristics	Concentration	Accessibility
Apr 30, 2014	Asbestos	<input type="checkbox"/>	Various Locations - ENCAPSULATED		

Accessibility: A - accessible to all building occupants, B - accessible to maintenance and operations staff only, C - accessible to maintenance and operations staff with a ladder only, D - not accessible due to physical barrier



Asbestos Register for 0022-24 N Bttlfrd - Cottage 5

Facility Type: Residence
Region: Saskatoon
Owner: Ministry of Central Services
Address: Sask Hospital Grounds , North Battleford S9A 2X8
Building Name: 0022-24 N Bttlfrd - Cottage 5
Contact Person: Sankey, Dan **Title:** Building Manager
Phone: 446-7792 **Email:** dan.sankey@gov.sk.ca

Date Reported	Type	Friable	Location / Characteristics	Concentration	Accessibility
Mar 15, 2013	Chrysotile	<input checked="" type="checkbox"/>	Cottage 5- Basement - Pipeline fitting on small line adjacent window		B
Mar 15, 2013	Chrysotile	<input checked="" type="checkbox"/>	Cottage 5- Furnace Room - Duct insulation		B

Accessibility: A - accessible to all building occupants, B - accessible to maintenance and operations staff only, C - accessible to maintenance and operations staff with a ladder only, D - not accessible due to physical barrier

Asbestos Register for 0022-25 N Bttlfrd - Cottage 6

Facility Type: Residence
Region: Saskatoon
Owner: Ministry of Central Services
Address: Sask Hospital Grounds , North Battleford S9A 2X8
Building Name: 0022-25 N Bttlfrd - Cottage 6
Contact Person: Sankey, Dan **Title:** Building Manager
Phone: 446-7792 **Email:** dan.sankey@gov.sk.ca

Date Reported	Type	Friable	Location / Characteristics	Concentration	Accessibility
Mar 15, 2013	Chrysotile	<input checked="" type="checkbox"/>	Cottage 6- Furnace Room - Duct insulation	80	B
Mar 15, 2013	Chrysotile	<input checked="" type="checkbox"/>	Cottage 6- Furnace Room - Pipeline fitting on small line, coming off of furnace	60	B
Mar 15, 2013	Chrysotile	<input checked="" type="checkbox"/>	Cottage 6- Furnace Room - Lineal pipe insulation from small line coming off of furnace	75	B
Mar 15, 2013	Chrysotile	<input type="checkbox"/>	Cottage 6- Main Floor Bedroom - 9" by 9" floor tile, brown with white streak		A

Accessibility: A - accessible to all building occupants, B - accessible to maintenance and operations staff only, C - accessible to maintenance and operations staff with a ladder only, D - not accessible due to physical barrier

Asbestos Register for 0022-26 N Bttlfrd - Cottage 10

Facility Type: Residence
Region: Saskatoon
Owner: Ministry of Central Services
Address: Sask Hospital Grounds , North Battleford S9A 2X8
Building Name: 0022-26 N Bttlfrd - Cottage 10
Contact Person: Sankey, Dan **Title:** Building Manager
Phone: 446-7792 **Email:** dan.sankey@gov.sk.ca

Date Reported	Type	Friable	Location / Characteristics	Concentration	Accessibility
Mar 15, 2013	Chrysotile	<input type="checkbox"/>	Cottage 10- Kitchen - 9" by 9" floor tile, blue with white streak	1 to 5	A
Mar 15, 2013	Chrysotile	<input checked="" type="checkbox"/>	Cottage 10- Furnace Room - Duct insulation	80	B

Accessibility: A - accessible to all building occupants, B - accessible to maintenance and operations staff only, C - accessible to maintenance and operations staff with a ladder only, D - not accessible due to physical barrier



Asbestos Register for 0022-27 N Bttlfrd - Cottage 11

Facility Type: Residence
Region: Saskatoon
Owner: Ministry of Central Services
Address: Sask Hospital Grounds , North Battleford S9A 2X8
Building Name: 0022-27 N Bttlfrd - Cottage 11
Contact Person: Sankey, Dan **Title:** Building Manager
Phone: 446-7792 **Email:** dan.sankey@gov.sk.ca

Date Reported	Type	Friable	Location / Characteristics	Concentration	Accessibility
Mar 13, 2013	Chrysotile	<input checked="" type="checkbox"/>	Cottage 11- Basement - Duct insulation		B
Mar 13, 2013	Chrysotile	<input type="checkbox"/>	Cottage 11- Kitchen - Sheet flooring, large brown square pattern		A

Accessibility: A - accessible to all building occupants, B - accessible to maintenance and operations staff only, C - accessible to maintenance and operations staff with a ladder only, D - not accessible due to physical barrier

Asbestos Register for 0022-28 N Bttlfrd - Cottage 12

Facility Type: Health Related Residence
Region: Saskatoon
Owner: Ministry of Central Services
Address: Sask Hospital Grounds , North Battleford S9A 2X8
Building Name: 0022-28 N Bttlfrd - Cottage 12
Contact Person: Sankey, Dan **Title:** Building Manager
Phone: 446-7792 **Email:** dan.sankey@gov.sk.ca

Date Reported	Type	Friable	Location / Characteristics	Concentration	Accessibility
Mar 15, 2013	Chrysotile	<input checked="" type="checkbox"/>	Cottage 12- Basement - Duct insulation	75	B

Accessibility: A - accessible to all building occupants, B - accessible to maintenance and operations staff only, C - accessible to maintenance and operations staff with a ladder only, D - not accessible due to physical barrier

Asbestos Register for 0022-35 N Bttlfrd - Cottage 20

Facility Type: Residence
Region: Saskatoon
Owner: Ministry of Central Services
Address: Sask Hospital Grounds , North Battleford S9A 2X8
Building Name: 0022-35 N Bttlfrd - Cottage 20
Contact Person: Sankey, Dan **Title:** Building Manager
Phone: 446-7792 **Email:** dan.sankey@gov.sk.ca

Date Reported	Type	Friable	Location / Characteristics	Concentration	Accessibility
Mar 13, 2013	Chrysotile	<input type="checkbox"/>	Cottage 20- Kitchen- Sheet flooring, multi - coloured stone pattern		A
Mar 13, 2013	Chrysotile	<input checked="" type="checkbox"/>	Cottage 20- Basement - Duct insulation	80	B

Accessibility: A - accessible to all building occupants, B - accessible to maintenance and operations staff only, C - accessible to maintenance and operations staff with a ladder only, D - not accessible due to physical barrier

Asbestos Register for 0022-44 N Bttlfrd - Chapel

Facility Type: Hospital
Region: Saskatoon
Owner: Ministry of Central Services
Address: Sask Hospital Grounds , North Battleford S9A 2X8
Building Name: 0022-44 N Bttlfrd - Chapel
Contact Person: Sankey, Dan **Title:** Building Manager
Phone: 446-7792 **Email:** dan.sankey@gov.sk.ca

Date Reported	Type	Friable	Location / Characteristics	Concentration	Accessibility
Mar 13, 2013	Chrysotile	<input checked="" type="checkbox"/>	Chapel- Morgue - Lineal pipe insulation from small line		A

Accessibility: A - accessible to all building occupants, B - accessible to maintenance and operations staff only, C - accessible to maintenance and operations staff with a ladder only, D - not accessible due to physical barrier

Asbestos Register for 0022-45 N Bttlfrd - Equipment Storage Hangar

Facility Type: Hospital
Region: Saskatoon
Owner: Ministry of Central Services
Address: Sask Hospital Grounds , North Battleford S9A 2X8
Building Name: 0022-45 N Bttlfrd - Equipment Storage Hangar
Contact Person: Sankey, Dan **Title:** Building Manager
Phone: 446-7792 **Email:** dan.sankey@gov.sk.ca

Date Reported	Type	Friable	Location / Characteristics	Concentration	Accessibility
Apr 30, 2014	Asbestos	<input type="checkbox"/>	Various Locations - ENCAPSULATED		

Accessibility: A - accessible to all building occupants, B - accessible to maintenance and operations staff only, C - accessible to maintenance and operations staff with a ladder only, D - not accessible due to physical barrier

Asbestos Register for 0022-46 N Bttlfrd - Garage/Storage

Facility Type: Hospital
Region: Saskatoon
Owner: Ministry of Central Services
Address: Sask Hospital Grounds , North Battleford S9A 2X8
Building Name: 0022-46 N Bttlfrd - Garage/Storage
Contact Person: Sankey, Dan **Title:** Building Manager
Phone: 446-7792 **Email:** dan.sankey@gov.sk.ca

Date Reported	Type	Friable	Location / Characteristics	Concentration	Accessibility
Mar 13, 2013	Chrysotile	<input checked="" type="checkbox"/>	Garage- Tool Room - Lineal pipe insulation from small line adjacent window	60	A
Mar 13, 2013	Chrysotile	<input checked="" type="checkbox"/>	Garage- Work Area - Pipeline fitting on medium line, above head adjacent unit heater	50	B

Accessibility: A - accessible to all building occupants, B - accessible to maintenance and operations staff only, C - accessible to maintenance and operations staff with a ladder only, D - not accessible due to physical barrier